



COOPER LIGHTING RECALLS EMERGENCY AND EXIT LIGHTS; COULD FAIL TO STAY ILLUMINATED IN AN EMERGENCY

Alert #08-598

The following product safety recall was voluntarily conducted by the firm in cooperation with the CPSC. Consumers should stop using the product immediately unless otherwise instructed.

Name of Product: "Sure-Lite" and "AtLite" Exit and Emergency Lights

Units: About 9,000

Distributor: Cooper Lighting Inc., of Peachtree City, Ga.

Hazard: The lights can malfunction and not stay illuminated in the event of a power failure. This could result in a failure to provide adequate lighting to guide building occupants to an exit in an emergency.

Incidents/Injuries: None reported.

Description: The recalled emergency and exit lights are installed in commercial buildings such as hotels and office buildings. The recall includes the following model numbers, which are written on the inside of the removable front cover.

12UEL1SD24X	CHEL1WHSDTDM	UEL1WHSDV
12UEL1SD24XTDM	UELBKSD	LPX70RBKDHS
12UEL1SD24XWH	UEL1BKSDHAZTDM	LPX70RBKDHS2146
6CHEL1SD24	UEL1BKSDTDM	LPX70RWHDS
6CHEL1SD24WH	UEL1SD	LPX70RWHDS2146
AEL1BKSD	UEL1SDA	LPX70RWHDSMRT
AEL1BZSD	UEL1SDAV	LPXH70RBKDHS
AEL1BZSDTDM	UEL1SDC	LPXH70RBKDHS284
AEL1SD	UEL1SDHAZ	LPXH70RBKSD
AEL1SDTDM	UEL1SDHAZTDM	LPXH70RWHDS
AEL1WHSD	UEL1SDTDM	LPXH70RWHDS212
AEL1WHSDTDM	UEL1SDV	LPXH70RWHDS214
CHEL1BKSD	UEL1WHSD	LPXH70RWHDS2146
CHEL1SD	UEL1WHSDAV	LPXH70RWHDS284
CHEL1SDTDM	UEL1WHSDHAZ	LPXH70RWHDSMRT2139
CHEL1WHSD	UEL1WHSDTDM	LPXH70RWHSD

The date code is located inside the housing and is formatted as XXXX-DDD-YY. For example, the date code "6746-356-07" means the product was manufactured on the 356th day of 2007. Only products with date codes between the 240th day of 2007 and the 101st day of 2008 are included in the recall.

Sold to: Authorized distributors nationwide from September 2007 through June 2008. Distributors resold and installed the lights for between \$200 and \$500.

Manufactured in: China

Remedy: Cooper Lighting is contacting customers directly and is providing a free replacement product.

Consumer Contact: For additional information, contact Cooper Lighting at (800) 954-7228 from 8 a.m. to 5 p.m. ET Monday through Friday, or visit the firm's Web sites at www.surelites-lighting.com or www.atlite-lighting.com

To see this recall on CPSC's web site, including pictures of the recalled product, please go to:

<http://www.cpsc.gov/cpsc/pub/prerel/prhtml08/08598.html>



NYS Department of State

**OFFICE OF
FIRE PREVENTION
& CONTROL**

phone 518.474.6746

fax 518.474.3240

email fire@dos.state.ny.us